


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 12890

1. OWNER JOE SMITH ADDRESS AT WELL LOCATION LOT 268 WILSON RD
 MAILING ADDRESS PAHRUMP NV 89041

2. LOCATION NE 1/4 SW 1/4 Sec. 17 T. 20S N/S R. 53 E NYE County CLAY
 PERMIT NO. 36-291-28 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	2	2
CALICHIE		2	5	3
CLAY		5	20	15
CALICHIE		20	22	2
CLAY		22	43	21
CALICHIE		43	52	9
CLAY		52	87	35
CALICHIE	WB	87	92	5
CLAY		92	108	16
CALICHIE	WB	108	113	5
CLAY		113	124	11
CALICHIE	WB	124	126	2
CLAY		126	133	7
CALICHIE	WB	133	135	2
CLAY		135	140	5
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 12 1/4 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1 1/8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 JUN 2 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 5-12-94, 19____
 Date completed 5-18-94, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. INC. Contractor
 Address HCR 78 BOX 80358
PAHRUMP NV 89041

Nevada contractor's license number 30880
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller

Signed Thomas Dean
 By driller performing actual drilling on site or contractor
 Date 5-28-94