



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER William Coultrip ADDRESS AT WELL LOCATION Lot 17 Yucca Terrace  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 NW 1/4 Sec 29 T. 20S N/S R. 53 E. Nye County  
 PERMIT NO. 40-372-09 CALONDA Subdivision Name  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
caliche		3	5	2
CLAY		5	23	18
caliche		23	25	2
CLAY		25	72	47
caliche	WB	72	74	2
CLAY		74	96	22
caliche	WB	96	99	3
CLAY		99	113	14
caliche	WB	113	116	3
CLAY		116	134	18
caliche	WB	134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 170 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>3 3/8</u>	<u>16.94</u>	<u>.189</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Saw cut  
 Size perforation 1/8  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED

JUN 2 1994

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 4/20 1994  
 Date completed 4/23 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HER 78 Box 80358 Contractor  
Alvump NV 89041  
 Nevada contractor's license number 30680 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas P... By driller performing actual drilling on site or contractor  
 Date 5/23/94