

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 44742  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 12569

1. OWNER SEA Co ADDRESS AT WELL LOCATION 1600 N. N. 7100  
 MAILING ADDRESS 3021 S. Valley View #104  
WV ND 89103  
 2. LOCATION SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 20 T. 20 N. 61 E. CLARK County  
 PERMIT NO. MD-2406 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	5	
CLAY		5	10	
CLAY		10	12	
CLAY		12	16	
CLAY w/ some FINES		16	25	

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>PVC</u>	<u>0.40</u>	<u>0</u>	<u>15</u>

Perforations:  
 Type perforation Slotted Screen  
 Size perforation 1020  
 From 15 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 15 feet to 25 feet

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2-25, 1994  
 Date completed 2-25, 1994

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Webb Environmental Inc Contractor  
 Address 4301 S. Valley View #21  
WV ND 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0035639  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1M1910  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 2-18-94