MW-1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. [redacted] 44750
Permit No.
Basin 06

NOTICE OF INTENT NO. 22989

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ NE ¼ Sec. 13 T. 36 N/S R. 49 E. EUREKA County
PERMIT NO. 58354 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DARK GRAY ROCK		2024	2058	34
FRACTURED DARK GRAY ROCK		2058	2069	11
DARK GRAY ROCK		2069	2120	51
LIGHT GRAY ROCK SOME CALCITE		2120	2143	23
LIGHT GRAY ROCK		2143	2175	32
LT. GRAY ROCK FRACTURED		2175	2186	11
LT. GRAY ROCK		2186	2239	53
LT. GRAY ROCK FRACTURED		2239	2248	9

'94 JUN 23 A11:57 STATE ENGINEER'S OFFICE

Date started APRIL 19, 1994
Date completed MAY 4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
deepened by log	120226	

8. WELL CONSTRUCTION
Depth Drilled 2248 Feet Depth Cased 2248 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
46	0	72
31	72	2024
22	2024	2248

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	159	.375	0	72
24	95	.375	+2	2207
19	LOUVERED		2007	2248

Perforations:
Type perforation ROSCOE MOSS LOUVERED
Size perforation .128
From 2007 feet to 2248 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 2008 feet

9. WATER LEVEL
Static water level 1224 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1822
Signed Rod Thompson (By driller performing actual drilling on site or contractor)
Date 06/10/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627