PPW-43

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44767
Permit No. 55140
Basin 061

NOTICE OF INTENT NO. 26403

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ SW ¼ Sec. 19 T 36 N/S R 50 E EUREKA County
PERMIT NO. 55140 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FRACTURED BLACK ROCK		0	60	60
SOFT BLACK & BROWN ROCK		60	100	40
FRACTURED BROWN ROCK		100	120	20
BROWN & BLACK ROCK	TRACE	120	180	60
GRAY ROCK	"	180	260	80
GRAY & BROWN ROCK	"	260	300	40
BLACK & GRAY ROCK	"	300	320	20
BLACK ROCK	"	320	340	20
BLACK BROWN WHITE ROCK	"	340	360	20
HARD BLACK ROCK	"	360	400	40
GRAY & BLACK ROCK	"	400	420	20
HARD GRAY-GREENROCK	"	420	435	15
SOFT GRAY-WHITE ROCK	"	435	475	40
GRAY WHITE & BROWN ROCK	"	475	575	100
HARD GRAY & WHITE ROCK	"	575	675	100
BLACK GRAY & WHIROCK	"	675	695	20
GRAY CLAY WHITE & BLACK ROCK	20	695	715	20
BLACK GRAY & WHITE ROCK	20	715	735	20
BROWN-GRAY ROCK WITH CLAY	"	735	755	20
HARD BLACK ROCK	"	755	815	60
BLACK - GRAY ROCK	25	815	960	145
BLACK-GRAY & WHITE ROCK	35	960	1080	120

Date started APRIL 18, 1994
Date completed APRIL 26, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1080 Feet Depth Cased 1060 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12-1/4 Inches	0 Feet	50 Feet
8 Inches	50 Feet	1080 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	24.7	.322	0	50
4	18	SCH80	0	220

Perforations:
Type perforation SLOT
Size perforation 1/8"
From 220 feet to 1060 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No / Per Fax from Wayne. Matt
Depth of Seal ~~1/8"~~ 200
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200 feet to 1080 feet

9. WATER LEVEL
Static water level 680 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
Contractor
Address 2286 WEST 1500 SOUTH
Contractor
SALT LAKE CITY UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1829

Signed Todd Schmaldfelt
By driller performing actual drilling on site or contractor

Date 06/10/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627