WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44783
Permit No.
Basin 073

NOTICE OF INTENT NO. 15277

1. OWNER NDOT
MAILING ADDRESS LOVELOCK MAINTENANCE STA. LOVELOCK, NV.
ADDRESS AT WELL LOCATION SAME MW-6

2. LOCATION NE ¼ SW ¼ Sec. 27 T. 26 (N)S R. 31 E. PERSHING County
PERMIT NO. M/O 635 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN SILTY CLAY | | 0 | 18' | 18' |
| BROWN SAND | 22' | 18' | 30' | 12' |

RECEIVED
JUN 16 1994
STATE ENGINEER'S OFFICE

Date started 6/7, 1993
Date completed 6/7, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | N/A | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 8 | 0 | 30 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | SCH. 40 | PVC | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.02"
From feet to feet
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 8'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 30 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1667
Signed (By driller performing actual drilling on site or contractor)
Date 6/1/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627