washoe 4678

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 44793
Permit No.
Basin 084

NOTICE OF INTENT NO. 25231

1. OWNER Gene Speck
MAILING ADDRESS 5605 Axe Handle Rd
Reno NV 89510
ADDRESS AT WELL LOCATION Wilcox Ranch Rd
Palomino Valley NV 89510

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 21 N R. 22 E. Washoe County
PERMIT NO. (Issued by Water Resources) 77450 (Parcel No.) 09 Wilcox Ranch II (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dirt rock	NO	0	5	5
sand clay rock	NO	5	31	26
clay gravel	NO	31	41	10
gray decomposed granite	NO	41	86	45
yellow decomposed granite	NO	86	153	33
dark gray rock	NO	153	180	33
gray fractured rock	NO	180	240	60
gray + greenish clay	NO	240	270	30
brown + black rock	yes	270	281	11
gray clay	NO	281	283	2
red + brown rock	yes	283	290	7
red + brown clay	NO	290	294	4
dark gray clay	NO	294	295	1
brown clay + rock	NO	295	298	3
brown fractured rock	yes	298	310	12

Date started 3 26, 1994
Date completed 6 18, 1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	268	3

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	103
6	103	310

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	310

Perforations:
Type perforation factory Slotted
Size perforation 3/32
From 290 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 103
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ed Miller (Contractor)
Address P.O. 92
Smith NV 89444 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1806
Signed (By driller performing actual drilling on site or contractor)
Date 6-18-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627