



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24962

1. OWNER John + Terry Peters ADDRESS AT WELL LOCATION 1/2 mile North SR 140  
 MAILING ADDRESS PO Box DEMO, NV. 89407

2. LOCATION SW 1/4 NW 1/4 Sec. 22 T. 47 N. R. 30 E Humboldt County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. 02-051-14 Subdivision Name N/N

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Decomposed Granite clay		0	20	
Decomposed Granite		20	22	
25% S+G 25% Clay		22	65	
Decomposed Granite clay	XX	65	90	
Decomposed Granite clay	XX	90	120	
Decomposed Granite	XX	120	125	
Decomposed Granite	XX	125	146	

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11" Inches To 0 Feet 146' Feet  
 .....Inches.....Feet.....Feet  
 .....Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12</u>	<u>.188</u>	<u>+ 1</u>	<u>140'</u>

Perforations:  
 Type perforation Factor Saw Cuts  
 Size perforation 3/32  
 From 126' feet to 146' feet  
 From .....feet to .....feet  
 From .....feet to .....feet  
 From .....feet to .....feet  
 From .....feet to .....feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

JUN 20 P 2:54  
 RECEIVED  
 STATE ENGINEERS OFFICE

Date started 5-3- 1994  
 Date completed 5-4 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>	<u>UNKNOWN</u>	<u>3 hrs</u>

9. WATER LEVEL  
 Static water level 60' feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature COOL °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10760 Grass Valley Rd Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375  
 Signed [Signature]  
 Date 5-6-94