

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22892

1. OWNER John & Jeraline Anderson ADDRESS AT WELL LOCATION 4 ST OSINO  
 MAILING ADDRESS 336-10-OSINO ELKO NV 89801 W 1/2 Lot 8 Bk 39

2. LOCATION NW 1/4 NW 1/4 Sec 9 T. 35 N/S R. 55 E ELKO County \_\_\_\_\_  
 PERMIT NO. 35-039-130 Parcel No. \_\_\_\_\_ Subdivision Name M.R.#3  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sod		0	1	1
Cemented Gravel		1	80	79
CLAY		80	87	7
Cemented Gravel		87	167	80
SANDSTONE		167	185	18
Cemented Gravel		185	190	5
CLAY		190	198	8
Cemented Gravel		198	209	11
CLAY		209	215	6
Gravel SAND	X	215	240	25

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 60 Feet  
8 3/8 Inches 60 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>12.92</u>	<u>1.88</u>	<u>+2</u>	<u>240</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/16 x 3"  
 From 212 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 59  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 59 feet to 240 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address P.O. Box 525 Contractor  
ELKO NV 89803  
 Nevada contractor's license number 31904  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1584  
 Division of Water Resources, the on-site driller.  
 Signed Shaul Fertig  
 By driller performing actual drilling on site of contractor  
 Date 7-8-94

Date started 5-24 1994  
 Date completed 6-8 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40+</u>	<u>NA</u>	<u>4.5</u>

'94 JUL 15 AM 1:30  
 STATE ENGINEERS OFFICE