WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44810
Permit No.
Basin 049

I

NOTICE OF INTENT NO. 23306

1. OWNER HARRY BURNER
MAILING ADDRESS Unit 161 Box
Kitt Ridge Cyn

ADDRESS AT WELL LOCATION Blk 18 Lot 2
9 ST X CREE

2. LOCATION NW ¼ SE ¼ Sec. 33 T. 35 N/S R. 55 E/W Elko County

PERMIT NO. ____ (Issued by Water Resources) | 37-18-02-5 (Parcel No.) | Kitt Ridge (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6"	6
Lose Rock		6"	8'	7.5
Cemented sandstone		8'	258	250
And Clay Mix		[illegible]	[illegible]	[illegible]
Lose Gravel		258	260	2
Cemented sandstone		260	210	50

'94 JUN 13 P1:47
RECEIVED
STATE ENGINEERS OFFICE

Date started 5-6, 1994
Date completed 5-18, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
16	NA	5.5

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	60 Feet
8 7/8 Inches	60 Feet	310 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	310

Perforations:
Type perforation slots
Size perforation 3/16 x 3"
From 270 feet to 310 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 57
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 57 feet to 310 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [signature] Fertig Drilling Co
Contractor

Address PO Box 525
Contractor
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 31904

Nevada driller's license number issued by the Division of Water Resources, the ~~on-site~~ driller 1584

Signed [signature]
By driller performing actual drilling on site or contractor

Date 6-1-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627