WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44814
Permit No.
Basin 04

NOTICE OF INTENT NO. 22891

1. OWNER EVERETT M Woodworth
MAILING ADDRESS Unit 292 Box 2
Elko NV 89801

ADDRESS AT WELL LOCATION Lot 6 Blk 10
Crow AVE

2. LOCATION SW ¼ NE ¼ Sec. 19 T 35 N/S R 56 E/W Elko County
PERMIT NO. (Issued by Water Resources) 36-010-06-4 (Parcel No.) MOR # 4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	1	1
Cemented SANDSTONE		1	82	81
CLAY		82	84	2
Cemented Gravel & SAND		84	260	186
Loose Gravel	X	260	265	5
CLAY		265	270	5

Date started 6-14, 1994
Date completed 6-24, 1994

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
65+		6.5

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
8 3/8 Inches		60 Feet	270 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	270

Perforations:
Type perforation Slots
Size perforation 3/16 x 3"
From 245 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 63
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 63 feet to 270 feet
PER TELCON W/ FERTIG DRILLING MATT

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Co (Contractor)
Address P.O. Box 525 (Contractor)
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-11-94

STATE ENGINEER'S OFFICE JUL 15 '94 A11:30

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627