CUP-3

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44827
Permit No.
Basin 051

NOTICE OF INTENT NO. 25632

1. OWNER NEWMONT GOLD CO.
MAILING ADDRESS P.O. BOX 669
CARLIN NV 89822-0669

ADDRESS AT WELL LOCATION
NEWMONT GOLD MINE NEAR CARLIN

2. LOCATION NE 1/4 NE 1/4 Sec. 14 T. 35 N/S R. 50 E. EUREKA County
PERMIT NO. M/O 790 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY & BROWN ROCK		0	55	55
GRAY & BROWN ROCK				
TAN CLAY		55	80	25
BLACK ROCK		80	110	30
BLACK ROCK & CLAY		110	125	15
BLACK ROCK		125	150	25
BLACK ROCK & CLAY		150	165	15
BROWN & BLACK ROCK		175	200	25
BLACK ROCK & CLAY		200	250	50
BLACK BROKEN ROCK		250	280	30
BLACK ROCK & CLAY		280	300	20
BLACK-GRAY & WHITE				
ROCK FRACTURED		370	405	35

'94 JUN 23 A11:56 STATE

Date started MAY 18, 19 94
Date completed MAY 20, 19 94

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 405 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12-1/4 Inches	0 Feet	20 Feet
6-1/2 Inches	20 Feet	405 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	0	20
1-1/4	2	SCH40	0	380

Perforations:
Type perforation SLOTTED
Size perforation .125
From 380 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 370 feet to 405 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1717

Signed David Carey (By driller performing actual drilling on site or contractor)
Date 06/10/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627