REPORT NO. 94.48

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 44832
PERMIT NO.
BASIN 089

NOTICE OF INTENT NO. 26117

1. OWNER Greg Sutton / Ruth Chan
MAILING ADDRESS 1524 Broadway Alameda, Ca 94501
ADDRESS OF WELL 4691 Cavataio
Carson City, Nv 89704

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 5 T 16N R 20 E Washoe COUNTY

PERMIT NO. PARCEL NO 050-302-29 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Grn & brn volc cobbles & boulders w/				
multi-colored volc sand & gravel w/		0		
brown & yellow clay		0	47	47
Grn, brn, purple, red & gray volc sand		47		
& gravel w/brown clay		47	127	80
Lt, dk green & brown-purple volc rock		127		
w/traces of green clay		127	172	45
Light green & purple volcanic rock		172	185	13
Lt grn, purple, yellow & brn volc rock		185	196	11
Semi-hard, fractured, blue-green &		196		
purple volcanic rock		196	235	39
Green, white, semi-hard, occasionally		235		
fractured granite		235	299	64

Notes :

'94 JUN 27 P1:59
STATE ENGINEER'S

Date Started 6/21/94 Date Completed 6/22/94

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	10+		2

8. WELL CONSTRUCTION

Depth Drilled 299 Depth Cased 299

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 62 Feet
8 1/2 Inches 62 Feet 299 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1.5	299

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 259 Feet to 279 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 53
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 53 Feet to 299 Feet

9. WATER LEVEL
Static Water Level 135 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature cool F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1511
Signed Roger Anthony
By driller performing actual drilling on site or contractor
Dated 6/23/94