

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **44842**
 Permit No. _____
 Basin **088**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24508

1. OWNER Beth Gingold
 MAILING ADDRESS 8200 Offenhouse Dr. Reno, NV 89501
 ADDRESS AT WELL LOCATION On Sylvester off Toll Rd. No address yet. Reno, NV 89511

2. LOCATION SE 1/4 SW 1/4 Sec. 34 T 18N N/S R. 20 F. Washoe County
 PERMIT NO. 17-200-04
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Brown top soil w/sand | | 0 | 5 | 5 |
| Tan clay | | 5 | 12 | 7 |
| Brown dirt/gray clay | | 12 | 20 | 8 |
| Redish purple hard rock | | 20 | 25 | 5 |
| Brown & Black rock w/ grey quartz | | 25 | 110 | 85 |
| Quartz w/more grey rock | | 110 | 140 | 30 |
| Grey rock & Clay | | 140 | 152 | 12 |
| Gray & Brn & Blk rock | | 152 | 180 | 28 |
| Gray rock & Clays | | 180 | 185 | 5 |
| Turquoise & black rock " with large fractures | xx | 185 | 207 | 22 |

8. WELL CONSTRUCTION
 Depth Drilled 207 Feet Depth Cased 207 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 1/2 Inches To 0 Feet 207 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.89</u> | <u>.188</u> | <u>0</u> | <u>207</u> |

Perforations:
 Type perforation Factory
 Size perforation 3/32 x 3"
 From 187 feet to 207 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 207 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MacKay Pump & Geothermal, Inc.
 Address 1600 Mt. Rose Hwy. Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 6-10-'94

Date started 6-3 1994
 Date completed 6-6 1994

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|---------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>30+</u> | | <u>2 hrs.</u> |

'94 JUN 16 P1:19
 STATE ENGINEER