

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26998

1. OWNER Steve King ADDRESS AT WELL LOCATION 3710 Lake Shore Dr.
 MAILING ADDRESS 2894 York Ave. Reno, Nev.

2. LOCATION N.E. 1/4 SW 1/4 Sec 6 T 16 N/S R. 20 E Washoe County
 PERMIT NO. 50-461-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Drain Clay</u>		<u>0</u>	<u>14</u>	<u>14</u>
<u>Sand + gravel</u>	<u>-</u>	<u>14</u>	<u>90</u>	<u>76</u>
<u>Blue clay</u>		<u>90</u>	<u>110</u>	<u>20</u>
<u>gravel</u>	<u>-</u>	<u>110</u>	<u>140</u>	<u>30</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory M.H.W.
 Size perforation 3/32
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 52
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 52 feet to 140 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow 710 G.P.M. _____ P.S.I.
 Water temperature 62.0 °F Quality check

Date started 6-3, 1994
 Date completed 6-4, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eaton Drilling Co. Contractor
 Address P.O. Box 1245 Dayton, Nev. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 4735A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 596
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-9-94