

OFFICE USE ONLY
 Log No. 44848
 Permit No. M/16683
 Basin 089

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27280

1. OWNER Parkview Estates ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS White Pine Drive
New Washoe City NV.
 2. LOCATION NW 1/4 SE 1/4 Sec 6 T. 16 S R. 20 E Washoe County
 PERMIT NO. M/16683 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Deepen

6. LITHOLOGIC LOG White Pine North

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|-------------|-------------|------------|
| <u>Rock Base</u> | <u>No</u> | <u>0</u> | <u>2.0</u> | <u>2.0</u> |
| <u>Silty Sand</u> | <u>No</u> | <u>2.0</u> | <u>8.0</u> | <u>6.0</u> |
| <u>Sand</u> | <u>No</u> | <u>8.0</u> | <u>9.5</u> | <u>1.5</u> |
| <u>Silty Sand</u> | <u>No</u> | <u>9.5</u> | <u>11.5</u> | <u>2.0</u> |
| <u>Sand</u> | <u>No</u> | <u>11.5</u> | <u>15.0</u> | <u>3.5</u> |
| <u>Silty Sand</u> | <u>Yes</u> | <u>15.0</u> | <u>18.0</u> | <u>3.0</u> |
| <u>Sand</u> | <u>Yes</u> | <u>18.0</u> | <u>25.0</u> | <u>7.0</u> |

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 35 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2</u> | <u>PVC</u> | <u>Sch. 40</u> | <u>0</u> | <u>35</u> |

Perforations:
 Type perforation Factory Slot
 Size perforation 1020 Inch.
 From _____ feet to _____ feet
 From 14.5 feet to 35 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 12
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 12 feet to 35 feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

Date started 7-7 1993
 Date completed 7-7 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>N/A</u> | <u>N/A</u> | <u>N/A</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andersen Exploration Drilling Contractor
 Address 1635 Bedford Rd. Reno NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1667
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6/11/94