WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74855
Permit No.
Basin 090

NOTICE OF INTENT NO. 25640

1. OWNER GAS-A-Mart Station/M.Michelsen
MAILING ADDRESS P.O. Box 2010
Stateline, NV 89449
ADDRESS AT WELL LOCATION 217 Kingsbury Dr
Stateline, NV 89449

2. LOCATION NW ¼ NW ¼ Sec. 26 T. 13 N/S R. 18 E. Douglas County
PERMIT NO. M/O-780-A Issued by Water Resources
NA Parcel No.
NA Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
VEW #3				
Asphalt		0	3"	3"
Sand & Gravel		3"	7'	6 3/4
Granite	75'	7'	85'	78'

Hole was sand packed with #8-12 silica sand, bentonite seal placed from -8 to -5, neat cement to surface monitor well monument cemented in flush with asphalt

Date started June 13, 1994
Date completed June 13, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	85 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	sch 40	0	85

Perforations:
Type perforation slots
Size perforation .020
From -10 feet to -85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From -8 feet to -85 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature cold °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING Contractor
Address P.O. Box 850 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-20-94

JUN 22 '94 AM 11:18 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627