

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25640

1. OWNER Gas-A-Mart Station/M. Michelsen ADDRESS AT WELL LOCATION 217 Kingsbury Dr.  
MAILING ADDRESS P.O. Box 2010 Stateline, NV 89449  
Stateline, NV 89449

2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 13 N. R. 18 E. Douglas County  
PERMIT NO. M/O-780-A NA Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
VEW #4				
Asphalt		0	3"	3"
Sand & Gravel		3"	11'	10 3/4'
Granite	72	11	80	69
Encountered Ground water at 72', hole was sand packed with #8-12 silica sand				
Bentonite seal placed from -5'6" to -8'				
Cement seal to surface monitor well monument cemented in flush with asphalt				

8. WELL CONSTRUCTION  
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
6 Inches 0 Feet 80 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	sch 40	0	80

Perforations:  
Type perforation slots  
Size perforation .020  
From -10 feet to -80 feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 5'6"  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From -8 feet to -80 feet

9. WATER LEVEL  
Static water level 33' feet below land surface  
Artesian flow NA G.P.M. NA P.S.I.  
Water temperature cold °F Quality NA

Date started June 13, 1994  
Date completed June 13, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>NA</u>	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING INC Contractor  
Address P.O. Box 850 Contractor  
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582  
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1654

Signed John Craig Davis  
By driller performing actual drilling on site or contractor  
Date 6-20-94