

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25640

1. OWNER Gas-A-Mart Station/M. Michelsen ADDRESS AT WELL LOCATION 217 Kingsbury Dr
 MAILING ADDRESS P.O. Box 2010 Stateline, NV 89449

2. LOCATION NW 1/4 NW 1/4 Sec 26 T 13 N/S R 18 E Douglas County
 PERMIT NO. M/O-780-A NA NA
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
VIEW #6				
asphalt		0	3"	3"
sand and gravel		3"	5'	4 3/4'
granite	65'	5'	80'	75'
Hole was sand packed with #8-12 silica sand				
Bentonite seal placed from -8' to -6'				
Neat cement to surface monitor well monument cemented in flush with asphalt				
JUN 22 AM 11:18				

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 80 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 0 Feet 80 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	sch 40	0	80

Perforations:
 Type perforation slots
 Size perforation .020
 From -10 feet to -80 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 6' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From -8 feet to -80 feet

9. WATER LEVEL
 Static water level 41 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature cold °F Quality NA

Date started '94 June 14, 1994
 Date completed June 14, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>NA</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HACKWORTH DRILLING INC Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-20-94