

OFFICE USE ONLY  
 Log No. 74862  
 Permit No. \_\_\_\_\_  
 Basin 090

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25640

1. OWNER Gas-aMart Station/M. Michelsen ADDRESS AT WELL LOCATION 217 Kingsbury Dr  
 MAILING ADDRESS P.O. Box 2010 Stateline, NV 89449  
 2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 13 N. R. 18 E Douglas County  
 PERMIT NO. M/O-780-A Parcel No. NA Subdivision Name NA  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
VEW #5				
Asphalt		0	3"	3"
sand and gravel		3"	9'	8 3/4'
granite	75	9	80	71
Hole was sand packed with #8-12 silica sand				
Bentonite seal placed from -8' to -5'				
Cement seal to surface monitor well monument cemented in flush with asphalt				

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 80 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 80 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	sch 40	0	80

Perforations:  
 Type perforation slots  
 Size perforation .020  
 From -10 feet to 80 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From -8 feet to -80 feet

Date started June 13, 1994  
 Date completed June 14, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>NA</u>	

9. WATER LEVEL  
 Static water level 42 feet below land surface  
 Artesian flow NA G.P.M. NA P.S.I.  
 Water temperature Cold °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name HACKWORTH DRILLING Contractor  
 Address P.O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6-20-94