

OFFICE USE ONLY  
 Log No. 44865  
 Permit No. \_\_\_\_\_  
 Basin. 087

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Greyhound ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 460 West Second Street  
Reno, NV  
 2. LOCATION 1/4 NW 1/4 SW 1/4 Sec. 11 T. 19 S. R. 19 E. Washoe County  
 PERMIT NO. MW-175-A Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. MW-8 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete		0	.75'	.75'
Gravel fill		.75'	2'	1.25'
Gravel fill w/ Fine sands		2'	7'	5'
Cobble & Boulder fragments		7'	12'	5'
Cobble & Boulder fragments - Gray in color		12'	28'	16'

8. WELL CONSTRUCTION  
 Depth Drilled 28' Feet Depth Cased 28 Feet  
 HOLE DIAMETER (BIT SIZE)  
8 Inches From 0 Feet To 28 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>1</u>	<u>Sch. 40</u>	<u>0</u>	<u>28</u>

Perforations:  
 Type perforation Slotted  
 Size perforation .020  
 From 13 feet to 28 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 11'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 11 feet to 28 feet

Date started June 2nd 1994  
 Date completed June 2nd 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>12.5 Gal</u>		<u>1</u>

9. WATER LEVEL  
 Static water level 20.268 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 65 °F Quality Cloudy

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Gregory J. Lawler Contractor  
 Address 1860 Obispo Ave Unit H  
Signal Hill CA 90804 Contractor  
 Nevada contractor's license number 34699  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1871  
 Signed Gregory J. Lawler  
 By driller performing actual drilling on site or contractor  
 Date 6-2-94