WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44869
Permit No.
Basin 092A

NOTICE OF INTENT NO. 26478

1. OWNER LOU & JUDY DOVER/DOVER CONSTR.
MAILING ADDRESS 16395 Rhyolite Cir.
Reno, NV 89511

ADDRESS AT WELL LOCATION 10820 PLata Mesa
Reno, NV 89506

2. LOCATION SW ¼ NE ¼ Sec. 25 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-174-12 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
White sandy clay		2	11	9
Brown sandy clay		11	20	9
Green sandy clay		20	39	19
Brown sandy clay		39	56	17
~~Granite sand~~ Brown clay		56	91	35
Granite sand	X	91	103	12
Brown clay		103	116	13
Soft zone, granite sands	X	116	119	3
Brown clay		119	123	4
Soft zone, granite sands	X	123	128	5
Brown clay		128	130	2

Date started 6-2-94, 19
Date completed 6-3-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	130 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	130

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 85 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. 17 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date June 7, 1994

JUN 13 P 1:37 '94 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627