

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 18103

1. OWNER John Harrah Property ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 6001 Talbot Lane \_\_\_\_\_  
Reino NV \_\_\_\_\_  
2. LOCATION NW 1/4 SE 36 T 19 S R 19 E Washoe County \_\_\_\_\_  
PERMIT NO. M2 638 P Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other Auger

6. LITHOLOGIC LOG HW-10

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>	<u>No</u>	<u>0</u>	<u>1.5</u>	<u>1.5</u>
<u>sandy clay</u>	<u>No</u>	<u>1.5</u>	<u>5.0</u>	<u>4.5</u>
<u>Clayey Sand</u>	<u>No</u>	<u>5.0</u>	<u>8.0</u>	<u>3.0</u>
<u>Silty Sandy Gravel</u>	<u>Yes</u>	<u>8.0</u>	<u>17.0</u>	<u>5.0</u>
<u>Clayey Sandy Gravel</u>	<u>Yes</u>	<u>13.0</u>	<u>30.0</u>	<u>17.0</u>

8. WELL CONSTRUCTION  
Depth Drilled 30 Feet Depth Cased 30 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 0 Feet 30 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>Sch. 40</u>	<u>0</u>	<u>30</u>

Perforations:  
Type perforation Factory Slot  
Size perforation 0.20 Inch  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 25 feet to 30 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 24 feet  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 24 feet to 30 feet

RECEIVED  
JUN 16 1994

STATE ENGINEER'S OFFICE

Date started 6-23 1993  
Date completed 6-24 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
Static water level 8.7 feet below land surface  
Artesian flow N/A G.P.M. N/A P.S.I.  
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Anderson Explorations Drilling Contractor  
Address 1635 Bedford Rd. Reno NV Contractor  
Nevada contractor's license number issued by the State Contractor's Board 34525  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m 1667  
Signed John Anderson  
Date 6/11/94