

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **23287**

1. OWNER **UNOCAL #6979** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **425 PRATER WAY** \_\_\_\_\_  
**SPARKS, NV** \_\_\_\_\_  
 2. LOCATION **DA 1/4 BB 1/4 Sec 4 T 19** O/S R **20** E **WASHOE** County  
 PERMIT NO. **M/O 743** Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other **Auger**

6. LITHOLOGIC LOG **U-3**

| Material     | Water Strata | From   | To     | Thickness |
|--------------|--------------|--------|--------|-----------|
| ASPHALT      |              | 0      | 1/2'   | 1/2'      |
| GRAVEL BASE  |              | 1/2'   | 2 1/2' | 2'        |
| SILT         |              | 2 1/2' | 5'     | 2 1/2'    |
| SANDY GRAVEL |              | 5'     | 7'     | 2'        |
| SAND         |              | 7'     | 10'    | 3'        |
| SANDY GRAVEL |              | 10'    | 16'    | 6'        |
| SAND         |              | 16'    | 20'    | 4'        |
| SANDY GRAVEL |              | 20'    | 35'    | 15'       |

8. WELL CONSTRUCTION  
 Depth Drilled **35** Feet Depth Cased **35** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **8** Inches To **35** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <b>2</b>           | <b>SCH 40</b>       | <b>PVC</b>              | <b>0</b>    | <b>35</b> |

Perforations:  
 Type perforation **FACTORY SLOT**  
 Size perforation **0.02"**  
 From **23** feet to **35** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal **9'**  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From **9** feet to **35** feet

9. WATER LEVEL  
 Static water level **26** feet below land surface  
 Artesian flow **N/A** G.P.M. **N/A** P.S.I.  
 Water temperature **COLD** F Quality **N/A**

Date started **1/27**, 19**94**  
 Date completed **1/27**, 19**94**

7. WELL TEST DATA

| TEST METHOD:  | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |        |                               |              |
|   |        | <b>N/A</b>                    |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **ANDRESEN EXPLORATION DRILLING** Contractor  
 Address **1635 BELFORD RD.** Contractor  
**RENO, NV 89509**  
 Nevada contractor's license number **0034525** issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources **M1667**  
 Signed \_\_\_\_\_  
 Date **6/11/94**