MW #1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44886
Permit No.
Basin 087

NOTICE OF INTENT NO. 19571

1. OWNER Arco Oil # 2137
MAILING ADDRESS 1701 B Street Sparks Nevada
ADDRESS AT WELL LOCATION 1701 B Street Sparks Nev.

2. LOCATION NW ¼ NW ¼ Sec. 08 T 19 N/S R 20 E Washoe County
PERMIT NO. MO 796 (Issued by Water Resources) | 087 N19 E20 S BB (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Road Base Material		0'	3'	3'
Course Sand with Gravels - water first encountered at 12' BGS	12'	3'	12	9'
Course Sand and Gravels with intermittant Boulders 1 to 2' thick	~~12~~	12'	40'	28'

'94 JUL 14 AM 10:03
STATE ENGINEER

Date started 6-10, 1994
Date completed 6-11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		No tests conducted

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 3/8 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1"	S40 PVC	1/8"	0'	40'
2"	S40 PVC	1/8"	0'	20'

Perforations:
Type perforation Machine Slotted
Size perforation .010
From 37 1/2 feet to 40' feet
From 10 feet to 20' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 6'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 35' to 40' feet from 8' to 20' feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bayles Bros Drilling Co (Contractor)
Address 1703 S 4490 W (Contractor)
Salt Lake City Utah 84104
Nevada contractor's license number issued by the State Contractor's Board 5380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1883
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-6-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627