WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA M025
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 44888
Permit No.
Basin 087

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 19571

1. OWNER Arco Oil #2137
MAILING ADDRESS 1701 B Street
Sparks Nevada
ADDRESS AT WELL LOCATION 1701 B Street
Sparks Nevada

2. LOCATION NW ¼ NW ¼ Sec. 08 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. MO 796 (Issued by Water Resources)
087 N19 E20 08B (Parcel No.)
Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Monitor Test ☑ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Road base Mater		0	3	3
Sand + Gravel		3	9	6
Coarse Gravel and Sand with boulder 12"		9	40	31

8. WELL CONSTRUCTION
Diameter hole 7 7/8 inches Total depth 40 feet
Casing record 5" PVC
Weight per foot Thickness

Diameter	From	To
1" inches	0 feet	40 feet
2" inches	0 feet	20 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Neat Cement
Depth of seal 6 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 35 feet to 40 feet
" 8 " 20 "
Perforations:
Type perforation Machine Slotted
Size perforation .010
From 37 1/2 feet to 40 feet
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12' feet below land surface
Flow None G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boyles Bros Drilling (Contractor)
Address 1703 Ⓦ 1490 W Sec (Contractor)
Nevada contractor's license number 5380
Nevada contractor's drillers number
Nevada driller's license number M 1883 (Actual Driller)
Signed Gary K Hill (Contractor)
Date 7-6-94

Date started 6-12, 1994
Date completed 6-12, 1994

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
			None Conducted

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434