WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44897
Permit No.
Basin 092A

NOTICE OF INTENT NO. 26477

1. OWNER STAN & GWEN ROBERTSON
MAILING ADDRESS 10480 San Fernando
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SE ¼ Sec. 26 T. 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 087-364-02 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed sands		0	2	2
Brown sandy clay		2	19	17
Green sandy clay		19	36	17
Gray sandy clay		36	55	19
Gray clay		55	106	51
Soft zone, NO WATER, gray sand		106	110	4
Gray clay		110	173	63
Soft zone	X	173	180	7
Gray clay		180	189	9
Soft zone	X	189	193	4
Gray clay		193	200	7

'94 JUN 13 P1:37 STATE ENGINEER

Date started 5-31-94, 19
Date completed 6-01-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 155 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 123 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 1, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627