WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44921
Permit No.
Basin 087

NOTICE OF INTENT NO. 23282

1. OWNER HIDDEN VALLEY COUNTRY CLUB
MAILING ADDRESS 3575 E. HIDDEN VALLEY DR. RENO, NV.
ADDRESS AT WELL LOCATION MW-4 GOLF COURSE MAIN FACILITY SAME

2. LOCATION NE ¼ SE ¼ Sec. 27 T. 19 (N)/S R. 20 E. WASHOE County
PERMIT NO. M/O 648 B (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SILTY SAND	-	0	3'	3'
BROWN CLAYEY SILT	-	3'	13'	10'
BROWN SILTY GRAVELLY SAND	-	13'	14'	1'
CLAYEY SILT	-	14'	26'	12'
SILTY GRAVELLY SAND	-	26'	27'	1'
SANDY SILT	-	27'	29'	2'
RED VOLCANIC LAYER	-	29'	30'	1'
SILTY CLAY	-	30'	33'	3'
CLAY	-	33'	37'	4'
GRAVELLY SAND	37½	37'	38'	1'
SANDY CLAY		38'	60'	22'

Date started 7/22, 1993
Date completed 7/22, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	60

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	SCH. 40	PVC	0	60

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.02"
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes, ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8' feet to 60 feet

9. WATER LEVEL
Static water level 37½ feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1667
Signed (By driller performing actual drilling on site or contractor)
Date 6/1/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627