

OFFICE USE ONLY
 Log No. 44938
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24928

1. OWNER HEARTHSIDE HOMES ADDRESS AT WELL LOCATION 763 BUCKSKIN GARDNERVILLE
 MAILING ADDRESS MINDEN, NV

2. LOCATION NW 1/4 NW 1/4 Sec 19 T 12 N R 21 E DOUGLAS County
 PERMIT NO. 29-470-16 RUBENSTROTH Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	6	6
CLAY		6	17	11
SANDY CLAY w/GRAVEL		17	56	39
SANDY CLAY		56	117	61
CLAY		117	133	16
SANDY CLAY w/GRAVEL		133	142	9
CLAY		142	154	12
CEMENTED GRAVEL		154	193	39
CLAY		193	221	28
CEMENTED GRAVEL	✓	221	240	19

'94 MAY 23 P 4:12
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 15.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDD CO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore
 By driller performing actual drilling on site contractor
 Date 5-19-94

Date started 5-12, 19 94
 Date completed _____, 19 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>15+</u>	<u>-</u>	<u>1</u>