WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44004
Permit No.
Basin 101

NOTICE OF INTENT NO. 26494

1. OWNER Eric Robinson Construction
MAILING ADDRESS 3812 Boyer Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4165 Alcorn Road
Fallon, NV 89406

2. LOCATION NE ¼ NE ¼ Sec. 33 T 19 N/S X R 28 E Churhcill County

PERMIT NO. (Issued by Water Resources) 08-691-15 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand		0	10	10
Coarse Brown Sand		10	25	15
Brown Clay		25	30	5
Green & Brown CLay		30	40	10
Fine Gray Sand		40	43	3
Fine & Coarse Gray Sand		43	55	12
Gray Clay		55	60	5
Coarse Brown Sand	X	60	68	8

94 MAY 25 P1:17 STATE ENGINEER

Date started May 8, 19 94
Date completed May 8, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 68 Feet Depth Cased 68 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	68 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	63

Perforations:
Type perforation Well Screen
Size perforation .035
From 63 feet to 68 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 68 feet

9. WATER LEVEL
Static water level 11' 2" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date 5-17-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627