WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44967
Permit No.
Basin 101

NOTICE OF INTENT NO. 26518

1. OWNER Paul Shamlin
MAILING ADDRESS P.O. Box 541
Fallon, NV 89407

ADDRESS AT WELL LOCATION
1495 Rio Vista Drive
Fallon, NV 89406

2. LOCATION NE ¼ SW ¼ Sec 20 T 19 N/S R 29 E Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 007-471-39 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	2	2
Brown Sand		2	15	13
Brown Clay		15	20	5
Brown Sand		20	45	25
Fine Green Sand		45	50	5
Coarse Gray Sand		50	80	30
Brownish Gray Sand		80	85	5
Brown Sand		85	110	25
Green Clay		110	135	25
Basalt		135	145	10
Basalt Fracters	X	145	150	5

Date started May 2, 19 94
Date completed May 2, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	135	Feet
8 3/4	Inches	135	Feet	140	Feet
5 5/8	Inches	140	Feet	150	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	140
4 ½	11.35	.250	140	150

Perforations:
Type perforation Torch Cut
Size perforation 1/8
From 145 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date 5-17-94

MAY 25 P 1:17
STATE ENGINEER
'94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627