

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 00785

1. OWNER A-A Dairy ADDRESS AT WELL LOCATION 3550 Farzaym  
 MAILING ADDRESS 3550 Farzaym  
 2. LOCATION 1/4 Sec 20 T. 25 N. R. 21 E Churchill County  
 PERMIT NO. 53798 Issued by Water Resources Parcel No. 191 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sandy Clay		0	20	20
Brown Clay		20	30	10
Black Clay		30	100	70
Green Sand	X	100	118	18
Green Sandy Clay		120	143	23
Black Clay		143	164	21
Green Clay		164	355	191
Green Sand		355	375	20
Green Clay with				
Black Rock	X	375	395	20
Gray Clay		395	435	40
Green Sand	✓	435	480	45
Basalt		480	483	3
Green Clay		483	552	31
Basalt		552	557	5
Cemented Sand	✓	557	568	11

94 JUN 16 P 1:33  
 STATE DRILLERS

8. WELL CONSTRUCTION  
 Depth Drilled 568 Feet Depth Cased 568 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 556 Feet  
 From 3 Inches To 568 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>14.6</u>	<u>.188</u>	<u>1</u>	<u>556</u>

Perforations:  
 Type perforation .050 Screen  
 Size perforation  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 548 feet to 568 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 556  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 23 - 4 ft feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started March 6, 1994  
 Date completed May 1, 1994

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>180</u>	<u>110</u>		<u>3</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Contractor  
 Address Box 888 Contractor  
Fallon  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772  
 Signed Welsco  
 By driller performing actual drilling on site or contractor  
 Date May 7-94