WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44978
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 19149

1. OWNER Tom Morrison
MAILING ADDRESS 2210 Birch ST
Carson City, Nev 89701

ADDRESS AT WELL LOCATION 3470 6TH ST
Silver Springs Nev

2. LOCATION NE ¼ NW ¼ Sec 16 T 17 N/S R 25 E Lyon County
PERMIT NO. Issued by Water Resources | 17-351-09 Parcel No. | Lahontan Sub #2 Lot 79 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine-Coarse Sand		0	3	3
Hard Pan Clay-Sand		3	5	2
Brown Clay + Fine Sand		5	12	7
Fine Sand		12	18	6
Brown Clay		18	28	10
Fine-Coarse Sand		28	54	26
Bluish-Gray Clay		54	64	10
Fine-Coarse Sand Bluish-Gray		64	72	8
Bluish-Gray Clay		72	78	6
Brown Clay		78	104	26
Bluish-Gray Clay + Fine Sand		104	112	8
Fine-Coarse Sand Bluish-Gray		112	132	20
Brown Clay		132	134	2
Bluish-Gray Clay + Fine Sand		134	153	19
Fine-Coarse Sand Bluish-Gray		153	170	17
Coars Sand + Gravel	X	170	178	8
Fine-Coarse Sand		178	188	10
Brown Clay		188	205	17
Bluish-Gray Clay + Fine Sand		205	235	30
Sand-Coarse Sand + Gravel Tight with Clay		235	255	20
Coarse Sand + Gravel	X	255	279	24

Date started May-19, 1994
Date completed May-28, 1994

7. WELL TEST DATA
TEST METHOD ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	22	5'	1/2 HR
AIR LIFT	60+	100' Line	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 279 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	279 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+1	279

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 259 feet to 279 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 279 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. Bybee Lane Contractor
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed L. Ogden By driller performing actual drilling on site or contractor
Date 5-6-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627