

OFFICE USE ONLY
 Log No. 44983
 Permit No. _____
 Basin 8-102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24673

1. OWNER Bob Mattson ADDRESS AT WELL LOCATION 3125 E 3rd St.
 MAILING ADDRESS P.O. Box 20427 Silver Springs, NV 89429
Sparks, NV

2. LOCATION NW 1/4 NW SE 1/4 Sec 29 T 17 N S R 25 E Lyon County
 PERMIT NO. 17-173-06 Parcel No. _____ Subdivision Name Putman #2

Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>fine coarse sand</u>		<u>0</u>	<u>43</u>	<u>43</u>
<u>Brown clay with some sticks of fine sand</u>		<u>43</u>	<u>105</u>	<u>62</u>
<u>fine coarse sand</u>	<u>X</u>	<u>105</u>	<u>140</u>	<u>35</u>

'94 JUN 21 AIO 144
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 140
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:
 Type perforation Mill
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 97 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 6/13 1994
 Date completed 6/15 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18</u>	<u>1</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ACE Drilling & Dev. Contractor
 Address P.O. Box 668 Contractor
Silver Springs, NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 14299
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
 Signed H. L. [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/16