WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44984
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 22939

1. OWNER Al Beaupre
MAILING ADDRESS 2730 E. Antelope St. Silver Springs, NV 89429
ADDRESS AT WELL LOCATION 2730 E. Antelope St Silver Springs, NV 89429

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 17 N/S R 25 E Lyon County
PERMIT NO. N/A (Issued by Water Resources) 17-472-13 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Clay		10	15	5
Sand, Clay		15	53	38
Course Sand		53	105	52
Clay		105	117	12
Course Sand, Clay		117	130	13
Course Sand Gravel		130	138	8
Sand, Clay		138	162	24
Course Sand		162	170	8
Clay	181	170	181	11
(Sand, Gravels	199	181	199	18
↓				
"Course Sand"				

'94 MAY 23 P4:11
RECEIVED
STATE ENGINEERS OFFICE

Date started 4/19/94, 19
Date completed 4/20/94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90 - 95 gpm		4 ¼ hrs

8. WELL CONSTRUCTION
Depth Drilled 199 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
11 ¼ Inches From 1 Feet To 199 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1.88	13 lbs	+1	199

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 12" x 4 rows
From 179 feet to 199 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 199 feet

9. WATER LEVEL
Static water level 48' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO 599 (Contractor)
S.S. Nv 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/20/94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627