WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45049
Permit No.
Basin 105

NOTICE OF INTENT NO. 24485

1. OWNER Rick & Nicola Woodson
MAILING ADDRESS 2567 Snyder
Carson City NV. 89701

ADDRESS AT WELL LOCATION 2563 Snyder
Carson City NV. 89701

2. LOCATION SE ¼ SW ¼ Sec. 3 T. 14 N/S R. 20 E. Carson County
PERMIT NO. Issued by Water Resources | 10-491-17 Parcel No. | None Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	3	3
Hard pack DG Sand		3	18	15
Course DG Sands		18	74	56
DG Sands (Rusty) w/Areas of Clay		74	100	26
Large Course DG Gravels (Broken up) Rusty DG Sands	XXX	100	140	40
T.D. 140'				

'94 MAY 27 P1:57 STATE ENGINEER'S OFFICE

Date started 5-24, 1994
Date completed 5-26, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11¾	Inches	0	Feet	65	Feet
10¼	Inches	65	Feet	140	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	140

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. 5551 Hwy 50 East Carson City Nevada Contractor
Address Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael J Hack
By driller performing actual drilling on site or contractor
Date 5-26-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627