WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45159
Permit No.
Basin 1162

NOTICE OF INTENT NO. 13529

1. OWNER MORGAN RUSSLE
MAILING ADDRESS
ADDRESS AT WELL LOCATION PARCEL 16
PAHRUMP, NV 89041

2. LOCATION N-W ¼ N-W ¼ Sec. 13 T. 20 S N/S R. 52E E. NYE County
PERMIT NO. (Issued by Water Resources) 28-701-31 (Parcel No.) CHARELSTON PARK (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	8	8
GREY CLAY		8	25	17
BLUE CLAY		25	55	30
BROWN CLAY	X	55	80	25
GREY CLAY	X	80	140	60

RECEIVED
AUG 30 1994
Div. of Water Resources
Branch Office Las Vegas, NV

Date started July 15, 1994
Date completed July 19, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	1/2 hour

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	140

Perforations:
Type perforation FACTORY
Size perforation 3 X 16 X 4
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LARRY'S WATER WELL SERVICE (Contractor)
Address P.O. BOX 3392 (Contractor)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 1916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 0035901
Signed (By driller performing actual drilling on site or contractor)
Date August 18, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627