WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45476
Permit No.
Basin 212

NOTICE OF INTENT NO. 13082

1. OWNER BROADBENT + ASSOC. C/O WESTWOOD FINANCIAL
MAILING ADDRESS 11440 SAN VICENTE, STE. 200
LOS ANGELES, CA 90049

ADDRESS AT WELL LOCATION SUN EXPRESS
1562 NO. EASTERN AVE, LAS VEGAS NV

2. LOCATION NW ¼ NW ¼ Sec. 25 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2434 (Issued by Water Resources) 060-470-007 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-5
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND AND GRAVEL (SP)		0	6	6
SILTY CLAY (CL)		6	13	7
SILTY SAND (SM)		13	18	5
SAND-SILT-CLAY (ML)		18	30	12

RECEIVED
JUN 9 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started APRIL 21, 1994
Date completed APRIL 21, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.157	0	30

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-10'; 10'-12' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 12 feet to 30 feet

9. WATER LEVEL
Static water level 18.18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (Contractor)
Address 4670 SO. POLARIS AVE. (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1869
Signed (By driller performing actual drilling on site or contractor)
Date June 1, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627