WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45671
Permit No.
Basin 101

NOTICE OF INTENT NO. 26498

1. OWNER Ron Evans
MAILING ADDRESS 2995 Alcorn Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 455 Lewis Lane
Fallon, NV 89406

2. LOCATION NE ¼ SW ¼ Sec. 28 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources | 008-493-20 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	30	30
Fine Brown Sand		30	38	8
Black Clay		38	43	5
Gray Sand		43	50	7
Gray Clay		50	55	5
Gray Sand		55	74	19
Brown Clay		74	75	1
Brown COarse Sand	X	75	80	5

'94 JUL 18 P 4:54
STATE ENGINEER

Date started June 20, 19 94
Date completed June 20, 19 94

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	80 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	80

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 77 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 80 feet

9. WATER LEVEL
Static water level 8.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 7-13-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627