

N32 E55 15 DAAD

WHITE - DIVISION OF WATER RESOURCES  
CANARY - CLIENT'S COPY  
PINK - WELL DRILLER'S COPY

STATE OF NEVADA

OFFICE USE ONLY

U.S.G.S. NO. DIVISION OF WATER RESOURCES

Log No. 45931

Permit No. 7652

Basin 048

PRINT OR TYPE ONLY LOCATION UPDATE  
DO NOT WRITE ON BACK

### WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26548

1. OWNER TANGHAL, ALBERT ADDRESS AT WELL LOCATION NONE

MAILING ADDRESS Unit SE NE NE SE

2. LOCATION NE 1/4 SE 1/4 Sec 15 T1V 32 N32 E55 County ELKO

PERMIT NO. Lot 8, Blk 16, Unit 1 LUCKY NUGGET RANCHES  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Sandy clay		0	3	3
Coarse cemented gravel		3	24	21
Sand, clay & boulder		24	53	29
Coarse sand	Sgpm	53	55	2
Clay		55	85	30
Clay within beds of water bearing sand		85	105	20
Clay		105	110	
	T.D.	110		

8. WELL CONSTRUCTION  
Depth Drilled 110 Feet Depth Cased 112 Feet

HOLE DIAMETER (BIT SIZE)			
From	To	From	To
1.0 Inches	0 Feet	5.5 Feet	
6 Inches	5.5 Feet	11.0 Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	110

Perforations:  
Type perforation Torch cut  
Size perforation 1/8 x 4 x 2/PL  
From 52 feet to 66 feet  
From 80 feet to 106 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured (bailed down in order to pour)  Concrete Grout  
Gravel Packed:  Yes  No  
From 55 feet to 110 feet

9. WATER LEVEL  
Static water level 2.6 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING Co Contractor  
Address 203 Pine St. 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632  
Signed James V. Muth By driller performing actual drilling on site or contractor  
Date 7-29-94

Date started 7-12, 1994  
Date completed 7-20, 1994

7. WELL TEST DATA			
TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>34</u>	<u>15</u>	<u>2 hrs.</u>	