

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22196

1. OWNER Frewer Const ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 124 W Brooks \_\_\_\_\_  
Nth Las Vegas \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec 27 T. 38 N S R 56 E ELKO County  
 PERMIT NO. C137 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
CLAY		3	84	81
CLAY & SAND		84	140	56
CLAY		140	183	37
Fractured Granite	X	183	200	17
GRANITE		200	205	5

8. WELL CONSTRUCTION  
 Depth Drilled 205 Feet Depth Cased 205 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 3/4 Inches To 0 Feet 205 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>			<u>0</u>	<u>205</u>

Perforations:  
 Type perforation FACTORY  
 Size perforation \_\_\_\_\_  
 From 135 feet to 175 feet  
 From 175 feet to 195 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 205 feet

9. WATER LEVEL  
 Static water level 142 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 6-22 1994  
 Date completed 6-25 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>250</u>		<u>24</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name AAA Drilling Contractor  
 Address 181-14 W Butlion Contractor  
ELKO, NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 0020684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shane Bennett  
 By driller performing actual drilling on site or contractor  
 Date July - 1 - 94