WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46072
Permit No.
Basin 104

NOTICE OF INTENT NO.

1. OWNER Carson City School District
MAILING ADDRESS P. O. Box 603
Carson City, Nevada 89702

ADDRESS AT WELL LOCATION 604 W. Musser Street
Carson City, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 15 (N/S) R. 20 E. Carson City County
PERMIT NO. M/O-789 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
3 inches asphalt over 3 inches baserock		0.0	1.0	1.0
DARK BROWN CLAYEY SAND (SC) with gravel, loose, moist		1.0	18.0	17.0
Stratified by sand and clayey gravel below 7.0 feet				
BROWN SAND (SP) with gravel, dense, saturated		18.0	24.0	?
Water level	18.0	18.0	24.0	?

Date started May 10, 1994
Date completed May 10, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 24.0 Feet Depth Cased 24.0 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10.0	0.0	24.0

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.50	2.0	0.237	0.0	23.5

Perforations:
Type perforation Circumslot
Size perforation 0.02
From 9.0 feet to 24.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5.0
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6.0 feet to 24.0 feet

9. WATER LEVEL
Static water level 18.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pezonella Associates, Inc. (Contractor)
Address 520 Edison Way (Contractor)
Reno, Nevada 89502
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 4114
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/23/94

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627