

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26062

1. OWNER Jerry Em m ADDRESS AT WELL LOCATION
 MAILING ADDRESS _____ 1165 Silver Circle
Stagecoach Nev
 2. LOCATION SE 1/4 NE 1/4 Sec. 17 T 17 N/S R 23 E Lyon County
 PERMIT NO. _____ Dayton Valley Turf Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Cemented Gravel w/ saturated gravel zones</u>		<u>20</u>	<u>180</u>	<u>160</u>
	<u>60</u>			
	<u>90</u>			
	<u>140</u>			
	<u>150</u>			
	<u>170</u>			

'94 OCT 26 P 2:04
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 180 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1.888</u>	<u>+1</u>	<u>180</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 3/32
 From _____ feet to _____ feet
 From 140 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clear

Date started Sept 7, 1994
 Date completed Sept 8, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enke Drilling Contractor
 Address P.O. Box 1345 Contractor
Dayton, Nev 89403
 Nevada contractor's license number issued by the State Contractor's Board 4739A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
 Signed Lee A. Enke
 By driller performing actual drilling on site or contractor
 Date Sept 8 1994