WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46164
Permit No.
Basin 087

NOTICE OF INTENT NO. 155579

1. OWNER ECOL PARTNERSHIP
MAILING ADDRESS P. O. BOX 1209
RENO, NV. 89504

ADDRESS AT WELL LOCATION 654 BIGELOW WAY
SPARKS, NV. 89431

2. LOCATION SW ¼ NW ¼ Sec. 9 T. 19 N/S R. 20 E. WASHOE County
PERMIT NO. M/O 213 (Issued by Water Resources) 03231224 (Parcel No.) UNKNOWN (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL HAD A FLUSH MOUNTED WELL COVER WITH A PVC SCREW CAP AT SURFACE. THE CASING CAP ON THE BOTTOM WAS DRILLED OUT & THE 2" PVC CASING WAS PUMPED FULL OF NEAT CEMENT CIRCULATED FROM A DEPTH OF 27 FT. THE DRILLING WAS DONE USING "A" ROD WHICH IS 1 5/8" DIAMETER WITH A 1 7/8" TUNGSTEN CARBIDE INSERT DRILL BIT.				
THE CASING WAS CUT OFF 18" BELOW GROUND SURFACE AND A 36" DIAM. X 30" DEEP CONCRETE PLUG PLACED OVER THE CASING AS IT IS LOCATED IN A PARKING LOT. READI MIX CONCRETE WAS USED FOR THE SURFACE CAPPING PLUG.				

Date started 10-17, 1994
Date completed 10-17, 1994

7. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

8. WELL CONSTRUCTION
Depth Drilled 26.6 Feet Depth Cased 26.6 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
2	0	26.6

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2		1/4	0	26.6

Perforations:
Type perforation FACTORY SAW SLOTS
Size perforation 0.040"
From 15 feet to 23 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 13 Ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 26.6 feet

9. WATER LEVEL
Static water level 22.4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKENZIE CONSTRUCTION (Contractor)
Address P.O. BOX 1209 (Contractor)
RENO, NV. 89504
Nevada contractor's license number issued by the State Contractor's Board 4597
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1621
Signed Tom Cordova (By driller performing actual drilling on site or contractor)
Date 10-21-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627