

Silver State Speedway Test Hole #1 - Abandoned

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 46250
Permit No. _____
Basin. 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26918

1. OWNER Carson City ADDRESS AT WELL LOCATION South of Steward facility by Silver State Speedway
MAILING ADDRESS 3300 Butti Way Bldg #9, Carson City, NV 89710
2. LOCATION SE 1/4 NE 1/4 Sec. 5 T 14 S R 20 E Carson County
PERMIT NO. 60205T 60206T Silver State Speedway
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED Test Hole
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG sand w/some cobbles		0	66	66
Sandy clay w/some cobbles		66	84	18
Coarse DG sand cobbles w/clay streaks		84	108	24
Gray clay		108	110	2
DG & sand		110	175	65
Hard granite w/some clay streaks		175	264	89

Abandoned hole-ran tremie pipe to TD & pumped 9 bag sand grout to surface

*94 00 10 P 1:47
STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled 264 Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
Inches _____ Feet _____ Feet
Inches N/A Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		N/A		

Perforations:
Type perforation _____
Size perforation N/A
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal N/A Neat Cement
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow N/A G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address P. O. Box 590 Winnemucca, NV 89446 Contractor
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1562
Signed C. E. Epler
By driller performing actual drilling on site or contractor
Date 10-6-94

Date started Sept. 19, 1994
Date completed Sept. 22, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	