

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21576

1. OWNER Joyce Goddard ADDRESS AT WELL LOCATION same  
 MAILING ADDRESS 3895 Pershing  
Carson City, NV 89704  
 2. LOCATION SW 1/4 SE 1/4 Sec. 6 T. 16N N/S R. 20 E WASHOE County  
 PERMIT NO. 50-483-26 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tag inside of 8" @ 80'				
White sands, grey clays, large rocks scattered with red/white/turquoise rocks scattered to bottom.				
Occasional clay steaks	x	80	145	65
We cased this 8" well with 6 5/8" x .188 casing from to 4' from top.				
We blew about 5 gpm at 85' before drilling deeper.				

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
7 7/8 Inches 80 From 145 To Feet Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	145

Perforations:  
 Type perforation Factory  
 Size perforation .070 tripple row  
 From 65 feet to 75 feet  
 From 135 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 24 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality not tested

Date started 9-13, 1994  
 Date completed 9-13, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	41	2 hours

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MacKay Pump & Geothermal, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719  
 Signed R. Bruce Mackay  
 By driller performing actual drilling on site or contractor  
 Date 9-16-'94

'94 OCT 12 P1:10  
 STATE ENGINEERS OFFICE