WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46297
Permit No.
Basin ~~092A~~ 94

NOTICE OF INTENT NO. 22851

1. OWNER RICK & ANETTE NELSON
MAILING ADDRESS 6275 Chimney Drive
Sun Valley, NV 89433

ADDRESS AT WELL LOCATION Graham Lane
Reno, NV 89506

2. LOCATION SW ¼ SE ¼ Sec. 7 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-372-09 (Parcel No.) Red Rock Estates #2 parcel 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay		2	16	14
Brown Decomposed sands		16	19	3
Brown clay		19	61	42
Brown DG sands		61	70	9
Brown clay		70	121	51
Brown sandy clay		121	170	49
Soft zone	X	170	188	18
Brown sandy clay		188	190	2
Gray sandy clay		190	198	8
Soft zone	X	198	202	4
Gray sandy clay		202	215	13
Soft zone	X	215	235	20
Gray sandy clay		235	262	27
Soft zone	X	262	267	5
Gray sandy clay		267	275	8

'94 OCT -4 P 1:19
STATE ENGINEER'S OFFICE

Date started 9-22-94, 19
Date completed 9-27-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	275	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 175 feet to 195 feet
From 215 feet to 213 feet
From 255 feet to 275 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow G.P.M. 30+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 29, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627