

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27294

1. OWNER STEVE & ARLEEN CASTRO ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 23 York Way 10600 Adobe DR.
Sparks, Nevada 89431 Reno, NV 89506
 2. LOCATION NW 1/4 NW 1/4 Sec. 13 T 21N N/S R. 18E Washoe County
 PERMIT NO. 087-060-16 Silver Knolls/Red Rock
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	6	5
Decomposed granite		6	12	6
Brown clay		12	19	7
Brown sandy clay		19	27	8
Brown clay		27	42	17
Soft zone(no water)		42	46	4
Brown clay		46	64	18
Soft zone(no water)		64	66	2
Brown sandy clay		66	171	105
Brown sandy clay with some gravels		171	204	33
Brown sandy clay		204	241	37
Big gravels		241	245	4
Brown sandy clay		245	249	4
Soft zone, streaks of sand & gravels	X	249	341	92
Brown clay		341	350	9

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	350

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 265 feet to 345 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 350 feet

9. WATER LEVEL
 Static water level 249 feet below land surface
 Artesian flow _____ G.P.M. 47 P.S.I.
 Water temperature cold °F Quality clear

Date started 8-29-94, 19____
 Date completed 8-30-94, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
47		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 31, 1994