WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46382
Permit No.
Basin 092A

NOTICE OF INTENT NO. 27299

1. OWNER DOUG & LORI STEINSHOUER
MAILING ADDRESS 3765 Vantage
Reno, Nevada 89502

ADDRESS AT WELL LOCATION 125 Columbia Hill CRT.
Reno, Nevada 89506

2. LOCATION SE ¼ NW ¼ Sec. 31 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-342-12 (Parcel No.) Resd Rock estates #17 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Soft brown sandy clay		2	9	7
Brown clay		9	28	19
Sandy brown clay		28	71	43
Gray clay		71	127	56
Soft zone (APP 1 GPM)	X	127	130	3
Gray sandy clay		130	155	25
Soft zone (APP5 GPM)	X	155	160	5
Gray sandy clay		160	169	9
Soft zone (APP 19 GPM)	X	169	180	11
Gray sandy clay		180	200	20

'94 SEP 26 P 3:14
STATE ENGINEER

Date started 9-19-94, 19
Date completed 9-20-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	53	Feet
8 5/8	Inches	53	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 135 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 53
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 53 feet to 200 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date September 22, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627