WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46396
Permit No.
Basin 084

NOTICE OF INTENT NO. 17741

1. OWNER Rockwell International-Rocketdyne Div
MAILING ADDRESS 6633 Canoga Ave.
Canoga Park, CA 91303

ADDRESS AT WELL LOCATION former Rockwell Nevada field lab in Palamino Valley
Nevada 2640 Whiskey spr Rd

2. LOCATION SE ¼ NE ¼ Sec. 07 T. 22N N/S R. 22E E. Washoe County
PERMIT NO. WaiverM/O-431-B (Issued by Water Resources) | 77-320-0~~8~~9 (Parcel No.) | ~~n/a~~ Palamino V. Unit 11 7223 (Subdivision Name)

3. PS-1/V-1 WORK PERFORMED Area D
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Sand		0	20	med
Gravelly Sand		20	35	med
Clayey Sand		35	39	med
Clayey Silt/Silty clay		39	47	v.fine
Gravelly Sand		47	55.5	fine

Date started 6/3, 1994
Date completed 6/3, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 55.5 Feet Depth Cased 55.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8.75 Inches	0 Feet	55.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
2-3/8	sch40	n/a	0	55.5	PS-1
1-5/16	sch80	n/a	23	43.0	V-1

Perforations:
Type perforation factory sawed
Size perforation .020
From V-1 38.4 feet to 42.7 feet
From PS-1 50.4 feet to 54.6 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 34'
Placement Method: ☒ Pumped ☐ Poured
with V-1 2' and PS-1 5' bentonite barrier
Gravel Packed: ☒ Yes ☐ No
From V-1 36/PS- 48 feet to V-1 43/PS-1 55' feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 47.7 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hedman Drilling Co. (Contractor)
Address P.O. Box 726 (Contractor)
Lincoln, Ca 95648

Nevada contractor's license number issued by the State Contractor's Board 0033492
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1555

Signed Steve Hedman
By driller performing actual drilling on site or contractor
Date 6/3/94

(Rev. 3 91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627